Upstream Node	Downstream Node	Upstream Rim Elev (ft)	Upstream Invert (ft)	Downstream Rim Elev (ft)	Downstream Invert (ft)	Length (ft)	Diameter (in)	Slope (%) Material	Upstream HGL (ft)	Downstream HGL (ft)	UP Check	DN Check
CB #66	CB #67	421.46	415.38	421.46	415.04	27.00	24.00	1.24 RCP	416.98	416.98	ОК	ОК
CB #67	CB #68	421.46	414.54	421.48	414.49	11.02	24.00	0.50 RCP	416.51	416.46	ОК	ОК
CB #68	CB #69	421.48	414.29	420.47	414.11	35.49	30.00	0.50 RCP	416.04	416.01	ОК	ОК
CB #69	CB #73	420.47	413.91	414.14	408.18	160.79	30.00	3.56 RCP	415.38	409.97	OK	ОК
CB #73	CB #74	414.14	407.98	411.84	405.23	75.52	30.00	3.64 RCP	409.51	407.66	OK	ОК
CB #74	CB #76	411.84	405.03	411.00	402.66	151.40	30.00	1.57 RCP	406.88	404.87	ОК	ОК
CB #76	FES #77	411.00	402.46	401.00	399.20	65.37	30.00	4.99 RCP	403.44	400.15	OK	OK
EX. 18" OUT	CB #502	428.03	422.84	427.78	422.57	10.98	18.00	2.46 RCP	423.72	423.72	ОК	ОК

IMPORTANT NOTE REGARDING MH AND CETOP ELEVATIONS.
Manhole top elevations are software generated based on proposed roadway profile and distance from centerline. The elevations shown are reliable but must be field verified during construction staking prior to installation.

Catch basin top elevations are software generated based on the top, back of curb elevation. These elevations are found to be reliable during review, however some tops may require adjustment in the field. ALL RIM ELEVATIONS MUST EE FIELD VERIFIED DURING CONSTRUCTION STAKING PROCESS PRIOR TO INSTALLATION.

SEPARATION NOTES:

1. MINIMUM SEPARATION BETWEEN STORM DRAINAGE AND SANITARY SEWER IS 24 INCHES. 2. MINIMUM SEPARATION BETWEEN WATER AND STORM DRAINAGE IS 18 INCHES 3. MINIMUM SEPARATION BETWEEN WATER AND SANITARY SEWER IS 18 INCHES.

HYDRANT, METER, AND CLEAN-OUT NOTES.
ALL HYDRANTS, METERS, AND SEWER SERVICES ARE SHOWN ALL HYDRANTS, METERS, AND SEWER SERVICES ARE SHOWN AT APPROXIMATE LOCATIONS. HYDRANTS, AND METERS, ARE TO BE PLACED WITHIN THE RIGHT-OF-WAYAS INDICATED ON CITY OF RALEIGH DETAIL. SEWER SERVICE SHALL BE PLACED INSIDE LOT AS SHOWN ON CITY OF RALEIGH DETAIL. CONTRACTOR SHALL WERIFY AND CONFIRIN PROPER LOCATION ACCORDING TO MUNICIPALITY REQUIREMENTS PRIOR TO INSTALLATION. CONTRACTOR SHALL VERIFY PROPER LOCATION WITH MUNICIPALITY INSPECTOR PRIOR TO INSTALLATION.

SITE PERMITTING APPROVAL

Water and Sewer Permits (If applicable)

The City of Ralesch consents to the connection and extension of the City's Public Server Syst The City of Holeign consents to the connection and existence of the City's Prusings bewere styles as shown on this plan. The meternal and Construction methods used for this project shalt could be standards and specifications of the City's Public Ut/des Handbook. City of Rateligh Pul Ut/filtes Department Permit # \$ -4800

The City of Raleigh consents to like connection and extension of the City's Public Water System as shown on their plan. The material and Construction methods used for this project shall conform to the standards and specification of the City's Public Utilities Hendbook. City of Raleigh Public Utilities Department Permit IIF \(\frac{W-3767}{W-3767} \).

The City of Ratieigh consents to the connection to its public sever systems and extension of the private severe collection system as shown on time plain. The nutrienal and constructions methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Ratieigh Public Utilities Department Permit 8 if

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: Their approval is being issued electronically. This approval is valid only upon their signature of a City of Relategh Review Officer below. The City, will retain a copy of the approval primars. Any used authorized by this approval must proceed in accordance with the plans hard to file with the City. The electronic approval must proceed in accordance is with a Any modification to the approval once issued will invalidate this approval

City of Raleigh Development Approval_

Rateigh Water Review Officer

ATTENTION CONTRACTORS

sewer, and or reuse, as approved in these plans, is responsible for contucting the Public Utilities Department at (919) 996-4540 at least twenty four hours prior to beginning any of their constr

Failure to notify both City Departments in advance of beginning construction, will result in the issuance of monetary fines, and require reinstallation of any water or sewer facilities not inspected as a result of this notification failure

Failure to call for Inspection, Install a Downstream Plag, have Permitted Plans on the Jobsite, or any other Violation of City of Raleigh Standards will result in a Fine and Possible Exclusion from future work in the City of Raleigh



caaENGINEERS, Inc.




MAC MAC MAC MAC MAC MAC MAC By By By



Phase 3 Storm Drainage
Preserve at Jones Dairy, South
Preserve at Jones Dairy, LLC
Rolesville, Wake County, North Carolina



4 ob No.



IMPORTANT NOTE REGARDING MH AND CETOP ELEVATIONS.
Manhole top elevations are software generated tassed on proposed roadway profile and distance from centerline. The elevations shown are reliable but must be field verified during constriction staking prior

Catch basin top elevations are software generated based on the top, back of curb elevation. These elevations are found to be reliable during review, however some tops may require adjustment in the field.

ALL RIM ELEVATIONS MUST BE FIELD VERIFIED DURING CONSTRUCTION STAKING PROCESS PRIOR TO INSTALLATION

SEPARATION NOTES:

1 MINIMUM SEPARATION BETWEEN STORM DRAINAGE AND SANITARY SEWER IS 24 INCHES. 2 MINIMUM SEPARATION BETWEENWATER AND STORM DRAINAGE IS 18 INCHES.

3. MINIMUM SEPARATION BETWEENWATER AND SANITARY SEWER IS 18 INCHES.

HYDRANT, METER, AND CLEAN-OUT NOTES,
ALL HYDRANTS, METERS, AND SEWER SERVICES ARE SHOWN
AT APPROXIMATE LOCATIONS. HYDRANTS, AND METERS, ARE
TO BE PLACED WITHIN THE RIGHT-OF-WAYAS INDICATED ON
CITY OF RALEIGH DETAIL. SEWER SERVICESHALL BE PLACED
INSIDE LOT AS SHOWN ON CITY OF RALEIGH DETAIL.
CONTRACTOR SHALL VERIFY AND CONFIRM PROPER LOCATION
ACCORDING TO AN INNICIPALITY DECRIPORATES PRIOR AS ACCORDING TO MUNICIPALITY REQUIREMENTS PRIOR TO INSTALLATION. CONTRACTOR SHALL VERIFY PROPER LOCATION WITH MUNICIPALITY INSPECTOR PRIOR TO INSTALLATION

SITE PERMITTING APPROVAL

Water and Sewer Permits (If applicable)

The City of Releigh consents to the commercion and extension of the City's Public Water Syste as shown on this plain. The material and Construction methods used for this project shall confo so assessment the pain. The meaning also construction methods used for this project shall confirm to the standards and specifications of the Cdy's Public Utilities Handbook. City of Raleigh Public Utilities Department Permit # W-3767

The City of Raleigh consents to the connection to its public server system and extension of the private sewer collection system as shown on this plan. The material and const used for this project shall conform to the standards and specifications of the City's Public Utilite Stook City of Raleigh Public Utilities Department Permit #

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval. This approval is being issued electronically. This approval is valid only upor the signature of a City of Rakeigh Review Officer below. The City will relian a copy of the approved plans Any work authorized by this approval must proceed in accordance with the plans kept on the with the City. This electronic approval may not be edited once issued. Any modification to this

City of Raleigh Development Approval

Rateigh Water Review Officer

ATTENTION CONTRACTORS

sewer, and or reuse, as approved in these plans, is responsible for contucting the Public Utilities Department at (919) 996-4540 at least twenty four hours prior to beginning any of their construction.

Failure to notify both City Departments in advance of beginning construction, will result in the issuance of monetary fines, and require reinstallation of any water or sewer facilities not inspected as a result

Failure to call for Inspection. Install a Downstream Plug, have Permitted Plans on the Jobsite, or any other Violation of City of Raleigh Standards will result in a Fine and Possible Exclusion from future work in the City of Raleigh.




CAAENGINEERS, Inc.
Mcintyre, Settle, Crowley
PROFESSIONAL ENGINEERS




Phase 3 Storm Drainage Preserve at Jones Dairy, South Preserve at Jones Dairy, LLC Rolesville, Wake County, North Carolina

4 Job No.

Graphic Scale















Durom Drive
Preserve at Jones Dairy, South
Preserve at Jones Dairy, LLC
Rolesville, Wake County, North Carolina

3

ATTENTION CONTRACTORS

Raleigh Water Review Officer

The Construction Contractor responsible for the extension of was sewer, and/or reuse, as approved in these plans, is responsible for contacting the Public Utilities Department at (919) 996-4540 at least twenty four hours prior to beginning any of their construction

The City of Rateigh consents to the connection and extension of the City's Public Sewer System as shown on this plan. The material and Construction methods used for this project shall conform to the standards and specifications of the City's Public Uffilters Handback. City of Raleigh Public Utilities Department Perceit # \$-4800 The City of Ralleigh consents to the connection and extension of the City's Public Water System the stay of relating the medical and Construction methods used for this project shall conform to the standards and specifications of the Cely's Public Utilities Hamiltook. City of Raleiga Public Utilities Department Permit # W-3767.

The City of Rateigh consents to the connection to its public sewer system and extension of the The City of Nating Confection system as shown on this plan. The material and constructions nethods used for this project shall conform to the standards and specifications of the City's Public Utilities
Handbook. City of Raleigh Public Utilities Department Permit # CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION


Electronic Approvet. This approval is being assued electronically. This approval is valid only apon the signature of a City of Natesh Review Officer below. The City will retain a copy of the approved. plans. Any work authorized by this approved must proceed in accordance with the plans kept on the with the City. This electronic approval may not be edited once issued. Any modification to the


SITE PERMITTING APPROVAL Water and Sewer Permits (If applicable)

approval once assued will invalidate this approval City of Raleigh Development Approval_


Failure to notify both City Departments in advance of beginning construction, will result in the issuance of monerary fines, and require reinstallation of any water or sewer facilities not inspected as a result of this nonfication failure.

Failure to call for Inspection. Install a Downstream Plug have Permitted Plans on the Jobvite, or any other Violation of City of Raleigh Standards will result in a Fine and Possible Exclusion from future work in the City of Ruleigh





Horizontal Scale



Vertical Scale



IMPORTANT NOTE REGARDING MH AND CB TOP ELEVATIONS: Manhole top elevations are software generated based on proposed roadway profile and distance from centerline. The elevations shown are reliable but must be field verified during construction staking prior

Catch basin top elevations are software generated based on the top, back of curb elevation. These elevations are found to be reliable during review, however some tops may require adjustment in the field. ALL RIM ELEVATIONS MUST BE FIELD VERIFIED DURING CONSTRUCTION STAKING PROCESS PRIOR TO INSTALLATION.

IMPORTANT NOTE REGARDING WATER AND SEWER SERVICE
LOCATIONS:
Water and Sewer services are shown on each lot. It is genrally
preferable to have sewer services on the lower side of each lot. The
locations shown are approximate. Actual locations shall be based on
City of Raleigh requirements as shown in the City of Raleigh Public
Utilities Handbook and Standard Details
ALL WATER AND SEWER SERVICE LOCATIONS MUST BE FIELD
VERIFIED DURING CONSTRUCTION STAKING PROCESS AND
PRIOR TO INSTALLATION.

SEPARATION NOTES:

1. MINIMUM SEPARATION BETWEEN STORM
DRAINAGE AND SANITARY SEWER IS 24 INCHES.

2. MINIMUM SEPARATION BETWEEN WATER AND
STORM DRAINAGE IS 18 INCHES.

3. MINIMUM SEPARATION BETWEEN WATER AND
SANITARY SEWER IS 18 INCHES.

HYDRANT, METER, AND CLEAN-OUT NOTES:
ALL HYDRANTS, METERS, AND SEWER SERVICES ARE SHOWN AT APPROXIMATE LOCATIONS. HYDRANTS, AND METERS, ARE TO BE PLACED WITHIN THE RIGHT-OF-WAY AS INDICATED ON CITY OF RALEIGH DETAIL. SEWER SERVICE SHALL BE PLACED INSIDE LOT AS SHOWN ON CITY OF RALEIGH DETAIL CONTRACTOR SHALL VERIFY AND CONFIRM PROPER LOCATION ACCORDING TO MUNICIPALITY REQUIREMENTS PRIOR TO INSTALLATION. CONTRACTOR SHALL VERIFY PROPER LOCATION WITH MUNICIPALITY INSPECTOR PRIOR TO INSTALLATION.

Job No. Dwg No.



caaENGINEERS, Inc.

MAC MAC MAC MAC MAC By



South , LLC Carolina

Durom Drive
Preserve at Jones Dairy, Sc
Preserve at Jones Dairy, L
Rolesville, Wake County, North Carc

SITE PERMITTING APPROVAL

Water and Sever Permits (If applicable)

The City of Rateich consents to the connection and extension of the City's Public Sewer System are done on this plan. The makesal and Construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Hendbook. City of Raleigh Public Utilities Department Permit 6 S-4800

The City of Raleich consents to the connection and extension of the City's Public Water System the Usig or Adaptive Carbonia and Extensional and Extensional to the Usig's Public United Space and Construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Rateigh Public Utilities Department Permit # W-3767

The City of Rateigh consents to the connection to its public sewer system and extension of the the City of hosping correction to the contribution as to public stress system and extension and private severe collection system as shown on this plan. The metastic lend constructions methods used for this project shall confirm to the claimforth and specifications of the City's Public Utilities Handbook. City of Rateigh Public Utilities Department Perretit #

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval. This approval is being assued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on the with the City. This electronic approval may not be added once assued. Any modification to this approval once essued will available this approval.

City of Raleigh Development Approval

Raleigh Water Review Officer

ATTENTION CONTRACTORS

The Construction Contractor responsible for the extension of wat sewer, and/or reuse, as approved in these plans, is responsible for contacting the Public Utilities Department at (919) 996-4540 at least twenty four hours prior to beginning any of their construction

Failure to notify both City Departments in advance of beginning construction, will result in the issuance of monetary fines, and require reinstallation of any water or sewer facilities not inspected as a result of this notification failure.

Failure to call for Inspection Install a Downstream Plag have Permitted Plans on the Jobsite, or any other Violation of City of Raleigh Standards will result to a Fine and Possible Exclusion from future work in the City of Raleigh

3 Job No. O

REVISED

IMPORTANT NOTE REGARDING MH AND CB TOP ELEVATIONS. Manhole top elevations are software generated based on proposed roadway profile and distance from centerline. The elevations shown are reliable but must be field verified during construction staking prior

Catch basin top elevations are software generated based on the top, back of curb elevation. These elevations are found to be reliable during review, however some tops may require adjustment in the field. ALL RIM ELEVATIONS MUST BE FIELD VERIFIED DURING CONSTRUCTION STAKING PROCESS PRIOR TO INSTALLATION.

IMPORTANT NOTE REGARDING WATER AND SEWER SERVICE LOCATIONS: Water and Sewer services are shown on each lot. It is genrally

water and Sewer services are shown in each lot. It is gentally preferable to have sever services on the lower side of each hold. The locations shown are approximate. Actual locations shown are approximate. Actual locations shown are approximate. Actual locations shown are shown in the City of Raleigh Public City of Raleigh requirements as shown in the City of Raleigh Public Utilities Handhook and Standard Delatis!

VERIFIED DURING CONSTRUCTION STAKING PROCESS AND PRIOR TO INSTALLATION

SEPARATION NOTES:

1. MINIMUM SEPARATION BETWEEN STORM DRAINAGE AND SANITARY SEWER IS 24 INCHES. 2. MINIMUM SEPARATION BETWEEN WATER AND STORM DRAINAGE IS 18 INCHES

3. MINIMUM SEPARATION BETWEEN WATER AND SANITARY SEWER IS 18 INCHES.

HYDRANT, METER, AND CLEAN-OUT NOTES:
ALL HYDRANTS, METERS, AND SEWER SERVICES ARE SHOWN
AT APPROXIMATE LOCATIONS. HYDRANTS, AND METERS, ARE
TO BE PLACED WITHIN THE RIGHT-OF-WAY AS INDICATED ON
CITY OF RALEIGH DETAIL. SEWER SERVICE SHALL BE PLACED
INSIDE LOT AS SHOWN ON CITY OF RALEIGH DETAIL
CONTRACTOR SHALL VERIFY AND CONFIRM PROPER LOCATION
ACCORDING TO MUNICIPALITY REQUIREMENTS PRIOR TO
INSTALLATION. CONTRACTOR SHALL VERIFY PROPER
LOCATION WITH MUNICIPALITY INSPECTOR PRIOR TO
INSTALLATION

